



FIRELAB

CERTIFICATE

This is to certify that

Tornado Turbine Roof Ventilator

Tornado backdraft range: 300 mm to 715 mm
Material types: Aluminium
Zincalume
Galvanised

is classified as follows

Resistance to Heat: B 300
Aerodynamic Free Area: *CJC 1501.02 and ITM/VB 9606

When classified in accordance with

BS EN 12101-2:2003 Subclause 7.5

* Clause 6 performed by University of Stellenbosch

and tested in accordance with

Annexure G of **BS EN 12101-2**

Signed:

Report Number: **FTC16/218 (Rev 1)**

Report validity: **June 2022**

(For more detailed information refer to report number **FTC 16/218**)

Reg nr: 2005/087037/23 • Tel: +2712 349 2929 • info@firelab.co.za

WINDMASTER INTERNATIONAL (PTY) LTD.
13 SIMBA STREET, SEBENZA, EDENVALE • GAUTENG • +27 11 452 8256

